





AMENDMENTS	
A	ORIGINAL ISSUE
DRN	VZ
EXP	BTH
DATE	23.12.08
JR No	-
TITLE BLOCK MODIFIED & MINOR CHANGES	
M.A.E.	W.I.
DRN	BTH
EXP	D.H.
DATE	12.4.2010
JR No	-
CHANGED SCREW LOCATION AND FRAME	
M.A.E.	J.P.
DRN	BTH
EXP	D.H.
DATE	24.1.2011
JR No	-
CHANGE TO DRAWING TITLE SIZE	
M.A.E.	J.P.

NOTES:

1. ALL STEEL PLATES TO CONFORM TO AS 3678 GRADE 250 U.O.N.
2. ALL STEEL BARS AND SECTIONS TO CONFORM TO AS 3679 GRADE 250 U.O.N.
3. ALL FILLET WELDS TO BE 6mm CONTINUOUS U.O.N. AND ARE TO CONFORM TO AS 1554, PART 1, CATEGORY G.P. U.O.N.
4. ALL SHARP EDGES AND BURRS TO BE REMOVED.
5. ALL TAPER LOCK JOINT LENGTHS ARE NOMINAL U.O.N.
6. ALL STEEL TO BE FULLY HOT DIP GALVANIZED AFTER FABRICATION IN ACCORDANCE WITH AS 4680.
7. SECTIONS TO BE STAGGERED DURING ASSEMBLY TO PREVENT SEAM WELDS LINING UP.



©This drawing and the copyright therein is the property of Endeavour Energy and may not be copied, reproduced, altered, loaned or used without the written consent of Endeavour Energy.



Endeavour Energy

ORIGINAL SCALE	APPROVED BH
DRAWN PW	-
DATE 17.4.01	-
EXP PA	-

DOUBLE MACARTHUR OUTREACHES
GENERAL DETAIL

DO NOT SCALE
DIMENSIONS IN MILLIMETRES

REFERENCE DRAWINGS
AUTHORISED
W. Isley

MANAGER ASSET ENGINEERING 17.4.2001
A4 262720 D
SHEET No 1 OF 1 SHEETS