

Supply to consumers from street light columns

This is an addendum to the transitional provision provided in Technical Bulletin TB 0086 dated 14 October 2010.

1. Designs that have been certified and remain within their validity period of six months may continue into construction in accordance with the previous practice of allowing service connections from street light columns.
2. New designs submitted for certification up to 1 December 2010, may incorporate the previous practice of allowing service connections from street light columns.
3. Designs which have previously utilised service connections from street light columns and are submitted for re-certification prior to 1 January 2011 may incorporate the previous practice of allowing service connections from street light columns.
4. In all other cases design and construction must be aligned to the revised practice and service connections from street light columns will not be accepted.